


Dimensions for ducts for different service requirements

Type of service	A	B	C	D	E
Telecom service	150	750	150	150	100
Electric supply	150	750	150	150	100
Water supply	150	1000	150	150	100

Notes:

1. All dimensions are in millimeters unless otherwise stated.
2. For all pipe diameters, the clearance from the pipe to the sides and bottom of the trench is 150 mm.
3. All ducts to be cleaned and cleared of obstructions prior to testing.. Marker tape to be appropriate to service provided.
4. All ducts to have pull chord suitably tied off in boxes.
5. marker tape to be appropriate to service provided.
6. Inspection boxes to be provided as per scheme plan drawings.
7. Where full pathe width reinstatement is required, this will be specified by the Engineer

NO.	AMENDMENTS	DATE	CLIENT:			STANDARD ANCILLARY DRAWINGS	Ducts for Telecom, Eleetrical & Water Supply Standard details.			
			 REPUBLIC OF KENYA MINISTRY OF ROADS AND TRANSPORT P.O. BOX 30260-00100 NAIROBI				DRAWING NO.: WSCM/22/4/01			
								Date: Jan. 2024	Scale: N.T.S.	Sheet No.: 1/1